



# Correction Notice

---

Address: 4880 T ST SACRAMENTO CA 95819

Permit #:

Case #: 23-009185

Date: September 16, 2025

Inspector: Paul Lovato

Phone #: 916-808-5703

***The following item(s) require your attention:***


1. Remove unpermitted electrical in garage along with extension cords used as permanent power. If added electrical is needed, permits could be issued to add electrical to garage.
2. Exterior wall modified to create extra square footage to be put back in original condition or obtain building permits to legalize.
3. Repair dry rot at siding and trim on East side of dwelling.
4. Fence at Southwest corner to be a maximum height of 7'
5. Fascia repair at South side of dwelling.
6. Electrical and gas added for washer and dryer to be removed or permitted to add appliances. Appliances are to be approved for outdoor use.
7. Electrical service panel to have added electrical removed along with extension cords. Dead front to be installed. If added electricity is required, permits need to be obtained.
8. Added plumbing at back of property to create a shower to be removed or permitted.
9. Added electrical and plumbing at back workshop to be removed or permitted.
10. Workshop at back of property to be detached from garage and reduced to 120 Sq Ft or legalized by obtaining building permits.
11. Extension cords at front of dwelling to be removed. If added electricity is required, permits are required.

This Violation List of building code violations may be partial and does not exclude any code violations which may become apparent during further inspections or during the necessary rehab/repair work. Other building structural, electrical, plumbing or mechanical code violations may be identified upon further inspection. If a permit is required for repairs or rehab, it may be obtained at 300 Richards Blvd. 3rd floor. A complete inspection has been carried out with a list of violations, and all paperwork/plans may need to be submitted before a permit can be issued. The property is required to remain secured and always maintained. If this unit is vacated by current tenants, it shall not be rented to a new tenant until all violation items are repaired/completed, the permit has been finalized and case closed.









WARD III

ON

OFF

SIGNAL  
End of Cycle  
SOFTER

LOUDER

PUSH TO START

Small Load

WATER LEVEL

**Operating Suggestions**

**1. Select & Adjust**

**WATER LEVEL:** Adjust to load size.

**SPEEDS:** Adjust to fabric type.

**1/2 hr. AUTO 15M:** Adjust to fabric type.

**WASH / RINSE:** Heavy Duty, Normal, Handwash / Gentle.

**2. Select Cycle**

Choose water level for heavily soiled loads and hot time for extra cleaning.

**3. Pull Timer to Start - Push Timer to Stop**

**Diagnosis**

**Troubleshooting & Sounds and Leaks**

**WARNING** / **AVERTISSEMENT**





CAUTION  
DANGER OF ELECTRIC SHOCK

B

A

GROUND

120

120V

DO NOT REMOVE THIS LABEL  
IT CONTAINS IMPORTANT  
SAFETY INFORMATION